NC/QC/W-03/2018-19/AL-CB1a **Date: 17-04-2019**

1. TEST REPORT ON CEMENT CONCRETE CUBES:

Sub: Testing of Concrete Cubes (for 28days Compressive Strength).
{Project*: Developments of roads and drains from 1st cross to 10th cross in Attur Layout and surrounding areas in Ward no.03.}
Ref.: Material testing/PMC/W-03/18-19,
Report Required for: Assistant Executive Engineer,
Project Division, Yelahanka Zone,
BBMP, Bangalore.
Name of the Agency/Contractor*: Sri. Gopi Reddy.K, Bangalore.

RESULTS OF COMPRESSIVE STRENGTH ON CEMENT CONCRETE

CUBE SPECIMENS

Dimensions of Specimen : 150 X 150 X 150mm

Grade of Concrete* : M_{20}

TABLE 1.1:

Sl No	Location/ Identification*	Date of Casting*	Date of Testing	Age in Days	C/S Area in mm^2	Maximum Load in K.N	Compressive Strength (N/mm^2)	Avg. Value
1	001	20-03-19	17-04-19	28	22500	505	22.44	**22.37**
	002	"	"	"	"	495	22.00	
	003	"	"	"	"	510	22.67	

KIRAN. R
M.E. (Civil-Engg)

Asst. Executive Engineer
Project Division
Yelahanka Zone
Bangalore

For Newzen Consultants Bangalore

Proprietor

NEWZEN CONSULTANT BANGALORE, #13,10TH MAIN ROAD 2ND CROSS JNANAJYOTHI NAGARA, JNANABHARATHI, BANGALORE-560056. CELL NO: +91 8792620231, 080 23240187

NC/QC/W-03/2018-19/AL-CB2a **Date: 20-04-2019**

1. TEST REPORT ON CEMENT CONCRETE CUBES:

Sub: Testing of Concrete Cubes (for 28days Compressive Strength).

{Project*: Developments of roads and drains from 1st cross to 10th cross in Attur Layout and surrounding areas in Ward no.03.}

Ref.: Material testing/PMC/W-03/18-19,

Report Required for: Assistant Executive Engineer,
Project Division, Yelahanka Zone,
BBMP, Bangalore.

Name of the Agency/Contractor*: Sri. Gopi Reddy.K, Bangalore.

RESULTS OF COMPRESSIVE STRENGTH ON CEMENT CONCRETE

CUBE SPECIMENS

Dimensions of Specimen : 150 X 150 X 150mm

Grade of Concrete* : M_{20}

TABLE 1.1:

Sl No	Location/ Identification*	Date of Casting*	Date of Testing	Age in Days	C/S Area in mm^2	Maximum Load in K.N	Compressive Strength (N/mm^2)	Avg. Value
1	001	23-03-19	20-04-19	28	22500	515	22.89	**22.22**
	002	"	"	"	"	490	21.78	
	003	"	"	"	"	495	22.00	

KIRAN. R
M.E. (Civil-Engg)

Asst. Executive Engineer
Project Division
Yelahanka Zone
Bangalore

For Newzen Consultants Bangalore

Proprietor

NEWZEN CONSULTANT BANGALORE, #13,10TH MAIN ROAD 2ND CROSS JNANAJYOTHI NAGARA,
JNANABHARATHI, BANGALORE-560056. CELL NO: +91 8792620231, 080 23240187

NC/QC/W-03/2018-19/AL-CB3a **Date: 22-04-2019**

1. TEST REPORT ON CEMENT CONCRETE CUBES:

Sub: Testing of Concrete Cubes (for 28days Compressive Strength).

{Project*: Developments of roads and drains from 1st cross to 10th cross in Attur Layout and surrounding areas in Ward no.03.}

Ref.: Material testing/PMC/W-03/18-19,

Report Required for: Assistant Executive Engineer,
Project Division, Yelahanka Zone,
BBMP, Bangalore.

Name of the Agency/Contractor*: Sri. Gopi Reddy.K, Bangalore.

RESULTS OF COMPRESSIVE STRENGTH ON CEMENT CONCRETE

CUBE SPECIMENS

Dimensions of Specimen : 150 X 150 X 150mm

Grade of Concrete* : M_{20}

TABLE 1.1:

Sl No	Location/ Identification*	Date of Casting*	Date of Testing	Age in Days	C/S Area in mm^2	Maximum Load in K.N	Compressive Strength (N/mm^2)	Avg. Value
1	001	25-03-19	22-04-19	28	22500	505	22.44	**22.74**
	002	"	"	"	"	520	23.11	
	003	"	"	"	"	510	22.67	

KIRAN. R
M.E. (Civil-Engg)

Asst. Executive Engineer
Project Division
Yelahanka Zone
Bangalore

For Newzen Consultants Bangalore

Proprietor

NEWZEN CONSULTANT BANGALORE, #13,10TH MAIN ROAD 2ND CROSS JNANAJYOTHI NAGARA, JNANABHARATHI, BANGALORE-560056. CELL NO: +91 8792620231, 080 23240187

NC/QC/W-03/2018-19/AL-CB4a

Date: 25-04-2019

1. TEST REPORT ON CEMENT CONCRETE CUBES:

Sub: Testing of Concrete Cubes (for 28days Compressive Strength).
{Project*: Developments of roads and drains from 1st cross to 10th cross in Attur Layout and surrounding areas in Ward no.03.}
Ref.: Material testing/PMC/W-03/18-19,
Report Required for: Assistant Executive Engineer,
Project Division, Yelahanka Zone,
BBMP, Bangalore.
Name of the Agency/Contractor*: Sri. Gopi Reddy.K, Bangalore.

RESULTS OF COMPRESSIVE STRENGTH ON CEMENT CONCRETE CUBE SPECIMENS

Dimensions of Specimen : 150 X 150 X 150mm

Grade of Concrete* : M_{20}

TABLE 1.1:

Sl No	Location/ Identification*	Date of Casting*	Date of Testing	Age in Days	C/S Area in mm^2	Maximum Load in K.N	Compressive Strength (N/mm^2)	Avg. Value
1	001	28-03-19	25-04-19	28	22500	500	22.22	**22.30**
	002	"	"	"	"	515	22.89	
	003	"	"	"	"	490	21.78	

KIRAN. R
M.E, (Civil-Engg)

Asst. Executive Engineer,
Project Division
Yelahanka Zone
Bangalore

For Newzen Consultants Bangalore

Proprietor

NEWZEN CONSULTANT BANGALORE, #13,10TH MAIN ROAD 2ND CROSS JNANAJYOTHI NAGARA,
JNANABHARATHI, BANGALORE-560056. CELL NO: +91 8792620231, 080 23240187
EMAIL:newzen576@gmail.com

NC/QC/W-03/2018-19/AL-CB5a

Date: 02-05-2019

1. TEST REPORT ON CEMENT CONCRETE CUBES:

Sub: Testing of Concrete Cubes (for 28days Compressive Strength).

{Project*: Developments of roads and drains from 1st cross to 10th cross in Attur Layout and surrounding areas in Ward no.03.}

Ref.: Material testing/PMC/W-03/18-19,

Report Required for: Assistant Executive Engineer,
Project Division, Yelahanka Zone,
BBMP, Bangalore.

Name of the Agency/Contractor*: Sri. Gopi Reddy.K, Bangalore.

RESULTS OF COMPRESSIVE STRENGTH ON CEMENT CONCRETE CUBE SPECIMENS

Dimensions of Specimen : 150 X 150 X 150mm

Grade of Concrete* : M_{20}

TABLE 1.1:

Sl No	Location/ Identification*	Date of Casting*	Date of Testing	Age in Days	C/S Area in mm^2	Maximum Load in K.N	Compressive Strength (N/mm^2)	Avg. Value
1	001	04-04-19	02-05-19	28	22500	495	22.00	22.00
	002	"	"	"	"	505	22.44	
	003	"	"	"	"	485	21.56	

KIRAN. R
M.E, (Civil-Engg

Asst. Executive Engineer
Project Division
Yelahanka Zone
Bangalore

For Newzen Consultants Bangalore

Proprietor

NEWZEN CONSULTANT BANGALORE, #13,10TH MAIN ROAD 2ND CROSS JNANAJYOTHI NAGARA, JNANABHARATHI, BANGALORE-560056. CELL NO: +91 8792620231, 080 23240187
EMAIL:newzen576@gmail.com

NC/QC/W-03/2018-19/AL-CB6a

Date: 09-05-2019

1. TEST REPORT ON CEMENT CONCRETE CUBES:

Sub: Testing of Concrete Cubes (for 28days Compressive Strength).

{Project*: Developments of roads and drains from 1st cross to 10th cross in Attur Layout and surrounding areas in Ward no.03.}

Ref.: Material testing/PMC/W-03/18-19,

Report Required for: Assistant Executive Engineer,
Project Division, Yelahanka Zone,
BBMP, Bangalore.

Name of the Agency/Contractor*: Sri. Gopi Reddy.K, Bangalore.

RESULTS OF COMPRESSIVE STRENGTH ON CEMENT CONCRETE

CUBE SPECIMENS

Dimensions of Specimen : 150 X 150 X 150mm

Grade of Concrete* : M_{20}

TABLE 1.1:

Sl No	Location/ Identification*	Date of Casting*	Date of Testing	Age in Days	C/S Area in mm^2	Maximum Load in K.N	Compressive Strength (N/mm^2)	Avg. Value
1	001	11-04-19	09-05-19	28	22500	520	23.11	22.74
	002	"	"	"	"	505	22.44	
	003	"	"	"	"	510	22.67	

KIRAN. R
M.E, (Civil-Engg)

Asst. Executive Engineer
Project Division
Yelahanka Zone
Bangalore

For Newzen Consultants Bangalore

Proprietor

NEWZEN CONSULTANT BANGALORE, #13,10TH MAIN ROAD 2ND CROSS JNANAJYOTHI NAGARA,
JNANABHARATHI, BANGALORE-560056. CELL NO: +91 8792620231, 080 23240187
EMAIL:newzen576@gmail.com

NC/QC/W-03/2018-19/AL-CB7a **Date: 14-05-2019**

1. TEST REPORT ON CEMENT CONCRETE CUBES:

Sub: Testing of Concrete Cubes (for 28days Compressive Strength).

{Project*: Developments of roads and drains from 1st cross to 10th cross in Attur Layout and surrounding areas in Ward no.03.}

Ref.: Material testing/PMC/W-03/18-19,

Report Required for: Assistant Executive Engineer,
Project Division, Yelahanka Zone,
BBMP, Bangalore.

Name of the Agency/Contractor*: Sri. Gopi Reddy.K, Bangalore.

RESULTS OF COMPRESSIVE STRENGTH ON CEMENT CONCRETE

CUBE SPECIMENS

Dimensions of Specimen : 150 X 150 X 150mm

Grade of Concrete* : M_{20}

TABLE 1.1:

Sl No	Location/ Identification*	Date of Casting*	Date of Testing	Age in Days	C/S Area in mm^2	Maximum Load in K.N	Compressive Strength (N/mm^2)	Avg. Value
1	001	16-04-19	14-05-19	28	22500	495	22.00	**22.44**
	002	"	"	"	"	520	23.11	
	003	"	"	"	"	500	22.22	

KIRAN. R
M.E, (Civil-Engg)

For Newzen Consultants Bangalore

Asst. Executive Engineer
Project Division
Yelahanka Zone
Bangalore

Proprietor

NEWZEN CONSULTANT BANGALORE, #13,10TH MAIN ROAD 2ND CROSS JNANAJYOTHI NAGARA,
JNANABHARATHI, BANGALORE-560056. CELL NO: +91 8792620231, 080 23240187
EMAIL:newzen576@gmail.com

NC/QC/W-03/2018-19/AL-CB8a **Date: 18-05-2019**

1. TEST REPORT ON CEMENT CONCRETE CUBES:

Sub: Testing of Concrete Cubes (for 28days Compressive Strength).
{Project*: Developments of roads and drains from 1st cross to 10th cross in Attur Layout and surrounding areas in Ward no.03.}
Ref.: Material testing/PMC/W-03/18-19,
Report Required for: Assistant Executive Engineer,
Project Division, Yelahanka Zone,
BBMP, Bangalore.
Name of the Agency/Contractor*: Sri. Gopi Reddy.K, Bangalore.

RESULTS OF COMPRESSIVE STRENGTH ON CEMENT CONCRETE

CUBE SPECIMENS

Dimensions of Specimen : 150 X 150 X 150mm

Grade of Concrete* : M_{20}

TABLE 1.1:

Sl No	Location/ Identification*	Date of Casting*	Date of Testing	Age in Days	C/S Area in mm^2	Maximum Load in K.N	Compressive Strength (N/mm^2)	Avg. Value
1	001	20-04-19	18-05-19	28	22500	510	22.67	**22.15**
	002	"	"	"	"	485	21.56	
	003	"	"	"	"	500	22.22	

KIRAN. R
M.E, (Civil-Engg)

Asst. Executive Engineer
Project Division
Yelahanka Zone
Bangalore

For Newzen Consultants Bangalore

Proprietor

NEWZEN CONSULTANT BANGALORE, #13,10TH MAIN ROAD 2ND CROSS JNANAJYOTHI NAGARA,
JNANABHARATHI, BANGALORE-560056. CELL NO: +91 8792620231, 080 23240187
EMAIL:newzen576@gmail.com

NC/QC/W-03/2018-19/AL-CB9a

Date: 20-05-2019

1. TEST REPORT ON CEMENT CONCRETE CUBES:

Sub: Testing of Concrete Cubes (for 28days Compressive Strength).

{Project*: Developments of roads and drains from 1st cross to 10th cross in Attur Layout and surrounding areas in Ward no.03.}

Ref.: Material testing/PMC/W-03/18-19,

Report Required for: Assistant Executive Engineer,
Project Division, Yelahanka Zone,
BBMP, Bangalore.

Name of the Agency/Contractor*: Sri. Gopi Reddy.K, Bangalore.

RESULTS OF COMPRESSIVE STRENGTH ON CEMENT CONCRETE

CUBE SPECIMENS

Dimensions of Specimen : 150 X 150 X 150mm

Grade of Concrete* : M_{20}

TABLE 1.1:

Sl No	Location/ Identification*	Date of Casting*	Date of Testing	Age in Days	C/S Area in mm^2	Maximum Load in K.N	Compressive Strength (N/mm^2)	Avg. Value
1	001	22-04-19	20-05-19	28	22500	495	22.00	**22.07**
	002	"	"	"	"	505	22.44	
	003	"	"	"	"	490	21.78	

K.R
KIRAN. R
M.E. (Civil-Engg)

For Newzen Consultants Bangalore

Asst. Executive Engineer
Project Division
Yelahanka Zone
Bangalore

Proprietor

NEWZEN CONSULTANT BANGALORE, #13,10TH MAIN ROAD 2ND CROSS JNANAJYOTHI NAGARA,
JNANABHARATHI, BANGALORE-560056. CELL NO: +91 8792620231, 080 23240187
EMAIL:newzen576@gmail.com

NC/QC/W-03/2018-19/AL-CB10a

Date: 22-05-2019

1. TEST REPORT ON CEMENT CONCRETE CUBES:

Sub: Testing of Concrete Cubes (for 28days Compressive Strength).
{Project*: Developments of roads and drains from 1st cross to 10th cross in Attur Layout and surrounding areas in Ward no.03.}
Ref.: Material testing/PMC/W-03/18-19,
Report Required for: Assistant Executive Engineer,
Project Division, Yelahanka Zone,
BBMP, Bangalore.
Name of the Agency/Contractor*: Sri. Gopi Reddy.K, Bangalore.

RESULTS OF COMPRESSIVE STRENGTH ON CEMENT CONCRETE CUBE SPECIMENS

Dimensions of Specimen : 150 X 150 X 150mm
Grade of Concrete* : M_{20}

TABLE 1.1:

Sl No	Location/ Identification*	Date of Casting*	Date of Testing	Age in Days	C/S Area in mm^2	Maximum Load in K.N	Compressive Strength (N/mm^2)	Avg. Value
1	001	24-04-19	22-05-19	28	22500	510	22.67	**22.52**
	002	"	"	"	"	495	22.00	
	003	"	"	"	"	515	22.89	

K. R
KIRAN. R
M.E, (Civil-Engg)

For Newzen Consultants Bangalore

Asst. Executive Engineer
Project Division
Yelahanka Zone
BANGALORE

Proprietor

NEWZEN CONSULTANT BANGALORE, #13,10TH MAIN ROAD 2ND CROSS JNANAJYOTHI NAGARA, JNANABHARATHI, BANGALORE-560056. CELL NO: +91 8792620231, 080 23240187
EMAIL:newzen576@gmail.com

NC/QC/W-03/2018-19/AL-CB11a

Date: 24-05-2019

1. TEST REPORT ON CEMENT CONCRETE CUBES:

Sub: Testing of Concrete Cubes (for 28days Compressive Strength).
{Project*: Developments of roads and drains from 1st cross to 10th cross in Attur Layout and surrounding areas in Ward no.03.}
Ref.: Material testing/PMC/W-03/18-19,
Report Required for: Assistant Executive Engineer,
Project Division, Yelahanka Zone,
BBMP, Bangalore.
Name of the Agency/Contractor*: Sri. Gopi Reddy.K, Bangalore.

RESULTS OF COMPRESSIVE STRENGTH ON CEMENT CONCRETE

CUBE SPECIMENS

Dimensions of Specimen : 150 X 150 X 150mm

Grade of Concrete* : M_{20}

TABLE 1.1:

Sl No	Location/ Identification*	Date of Casting*	Date of Testing	Age in Days	C/S Area in mm^2	Maximum Load in K.N	Compressive Strength (N/mm^2)	Avg. Value
1	001	26-04-19	24-05-19	28	22500	500	22.22	**22.30**
	002	"	"	"	"	520	23.11	
	003	"	"	"	"	485	21.56	

KIRAN. R
M.E, (Civil-Engg)

For Newzen Consultants Bangalore

Asst. Executive Engineer
Project Division
Yelahanka Zone
Bangalore

Proprietor

NEWZEN CONSULTANT BANGALORE, #13,10TH MAIN ROAD 2ND CROSS JNANAJYOTHI NAGARA, JNANABHARATHI, BANGALORE-560056. CELL NO: +91 8792620231, 080 23240187

NC/QC/W-03/2018-19/AL-CB12a

Date: 27-05-2019

1. TEST REPORT ON CEMENT CONCRETE CUBES:

Sub: Testing of Concrete Cubes (for 28days Compressive Strength).

{Project*: Developments of roads and drains from 1st cross to 10th cross in Attur Layout and surrounding areas in Ward no.03.}

Ref.: Material testing/PMC/W-03/18-19,

Report Required for: Assistant Executive Engineer,
Project Division, Yelahanka Zone,
BBMP, Bangalore.

Name of the Agency/Contractor*: Sri. Gopi Reddy.K, Bangalore.

RESULTS OF COMPRESSIVE STRENGTH ON CEMENT CONCRETE

CUBE SPECIMENS

Dimensions of Specimen : 150 X 150 X 150mm

Grade of Concrete* : M_{20}

TABLE 1.1:

Sl No	Location/ Identification*	Date of Casting*	Date of Testing	Age in Days	C/S Area in mm^2	Maximum Load in K.N	Compressive Strength (N/mm^2)	Avg. Value
1	001	29-04-19	27-05-19	28	22500	500	22.22	**22.15**
	002	"	"	"	"	505	22.44	
	003	"	"	"	"	490	21.78	

KIRAN. R
M.E, (Civil-Engg)

For Newzen Consultants Bangalore

Asst. Executive Engineer
Project Division
Yelahanka Zone
Bangalore

Proprietor

NEWZEN CONSULTANT BANGALORE, #13,10TH MAIN ROAD 2ND CROSS JNANAJYOTHI NAGARA, JNANABHARATHI, BANGALORE-560056. CELL NO: +91 8792620231, 080 23240187
EMAIL:newzen576@gmail.com